

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1429:111 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Secutron Inc., 70 Esna Park Dr., Unit 14, Markham, Ontario Canada, L3R 6E7
Contact: *Paul Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Models MRL-ST1-15, MRL-ST1-1575, MRL-ST1-30, MRL-ST1-60, MRL-ST1-75, MRL-ST1-110, MRL-ST2-15, MRL-ST2-1575, MRL-ST2-30, MRL-ST2-60, MRL-ST2-74 and MRL-ST2-110 strobe lights; followed by suffix -W (wall mount), followed by -W or -R (white or red). Intended for indoor use and wall mount only. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: 15cd, 15cd & 75cd at 0° angle axis
30cd, 60cd, 75cd, 110cd
Electrical: 21-30 VDC
Flash Rate: 60 flashes per minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and candela ratings and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired for use with separately listed compatible fire alarm control units. For indoor use and wall mount only.

XLF: 7125-0569:123

*Rev. 09-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager